

# **Designing a Mined Geologic Disposal System— When is a Thermal Loading Decision Needed?**

**US Nuclear Waste Technical Review Board  
Thermal Loading Meeting  
Denver, Colorado  
July 14, 1993**

**Larry Ramspott**

# **A Up-to-date Conceptual Design is Necessary to Conduct the Program Efficiently**

---

- **The site characterization plans, materials test plans, and the design of the storage, handling, and transportation sub-systems all are based on a repository conceptual design.**
- **The design in the 1988 Yucca Mountain SCP is out-of-date. New ideas:**
  - **Ramp versus shaft access for ESF**
  - **Drift vs borehole emplacement**
  - **Rail versus road underground access**
  - **MPC/MPU sealed at reactor for final disposal**
  - **Dry storage at the reactors**
  - **Extended performance of Engineered Barrier System**
  - **Extended Dry and "cold" concepts of heat management**
  - **Acknowledgement that average age of waste at emplacement will be 30 years, not 5 or 10.**
- **An up-to-date repository conceptual design is needed.**

# Effect of Thermal Loading on Repository Behavior in Unsaturated Tuff


---

- Under ambient conditions at Yucca Mountain, an opening into unsaturated tuff remains dry despite the rock's containing water in the pores.
- Introduction of heat into the rock mobilizes this water; under some circumstances it can drip into openings.
- Two other design input features are different for spent fuel in unsaturated tuff compared with reprocessed waste in salt or granite, which was the model in early thinking:
  - When heat in spent fuel is integrated for more than a hundred years, the majority of heat comes from actinides and persists for thousands of years
  - Unsaturated tuff has one-third the thermal conductivity of salt and two-thirds that of granite.
- Ambient conditions at Yucca Mountain will be perturbed for up to 100,000 years under all thermal loading options.

# WP Heat Load for PWR Spent Fuel




(SCP-CDR, 3kW @ 10y out of core)



## **Thermal Loading Concepts Fall into Three Groups**

- **The Site Characterization Plan Conceptual Design (SCP-CD)**
  - **Borehole emplacement of 10 years-out-of-core (YOC) spent fuel or high-level waste in thin wall, corrosion-resistant, unshielded containers at about 57 kW/acre, maximum drift wall about 130 C and maximum borehole wall about 230 C.**
- **Sub-boiling drift emplacement**
  - **Self-shielded casks containing 30 YOC fuel**
  - **Maximum 50 C, 1-4 PWR per cask, maximum 20 kW/acre**
  - **Maximum 90 C, 8-12 PWR per cask, maximum 40 kW/acre**
- **Extended Dry drift emplacement**
  - **Self-shielded casks containing 30 YOC fuel**
  - **Maximum 205 C allows 21-24 PWR per cask at 114 kW/acre**
  - **Maximum 125 C allows 21-24 PWR per cask at 57 kW/acre**

# Temperature history along the repository centerline for various thermal loading conditions at the repository horizon.



# **Issues Common to SCP reference, Extended Dry, and Sub-Boiling Repositories**

---

- **Heat will affect the system**
  - **The real question: is the effect deleterious?**
- **Water will be mobilized**
  - **Hydrologic behavior of the system must be predicted .**
- **Most of the water that affects the repository doesn't flow from the surface**
  - **Already underground.**
- **There will be zones where hot water contacts rock for decades.**
- **Saturated zone will be heated, resulting in convective flow.**

## **The Emergence of Drift Emplacement is Based on Many Features Beside Thermal Loading**

- **Cheaper and simpler**
- **Allows self-shielding, which makes retrievability more believable.**
- **Facilitates the use of a more robust waste package**
- **Makes the MPC/MPU concepts feasible.**
- **May reduce risk from seismic activity.**
- **Eliminates the "bathtub" scenario around a single waste package.**
- **May lessen consequences of human intrusion**

## **Drift emplacement facilitates both Extended Dry and sub-boiling repository concepts**

---

- **For the same peak wall-rock temperature**
  - drift emplacement allows a much greater loading density, which combined with older fuel facilitates the Extended Dry concept.
- **For the same loading density**
  - drift emplacement gives a lower peak wall-rock temperature, which combined with older fuel facilitates a sub-boiling repository.

## **The Main Distinction Between the Two Drift-Emplaced Options is Thermal Loading**

---

- For 30 year old fuel, Extended Dry ranges from 60 to 120 kW/acre whereas sub-boiling ranges from 20 to 40 kW/acre.
- The Extended Dry option implies a smaller area, less miles of drift, fewer but larger waste packages (therefore rail haulage), and a greater challenge to designing emplacement drift backfill.
- The sub-boiling option implies a larger area, more miles of drift, many more but smaller waste packages (possible non-rail haulage), and less difficulty to designing emplacement drift backfill.
- Only a detailed study would show how much similarity could exist for the two options (i.e., is a "generic" design possible?)
  - drift diameter and spacing?
  - ventilation requirements?
  - handling equipment?

# **Thermal Tests and a Thermal Loading Decision**

---

- **There would be no need for a thermal loading decision except for its potential effect on licensing for isolation. Otherwise, the most cost effective design would be automatically adopted.**
- **A specific thermal loading is needed for a final (licensing) repository design.**
- **At that point, a decision must be based on test data and analysis, not calculations alone.**
- **With respect to an earlier decision**
  - **Is a thermal loading decision needed for repository conceptual design?**
  - **If yes, are thermal test data needed for the decision?**
  - **If no, how can design of the storage and transportation sub-systems proceed?**

# The Technical Basis for a Final Thermal Loading Decision Does Not Exist at Present

---

- Debate about the SCP reference design vs a sub-boiling design vs Extended Dry misses the point — we don't understand any of these well enough at this time.
- Calculations of both the "cool" and SCP designs show effects from heat similar to those attributed to Extended Dry.
  - SCP: very high temperatures at rock wall
  - "Cool": long times with rock in contact with hot water
  - Both: perturbation of water flow in saturated zone, mobilization of water in unsaturated zone.
- Some of the thermal loading issues are not resolvable by more or better calculations.
- Therefore heater test results are needed to choose a final thermal loading strategy
  - how much testing of what kind for how long?
  - need formal analysis of several options for EIS.

# **Fortunately, a Thermal Loading Decision Is Not Needed for Conceptual Design**

---

- **What is needed for conceptual design**
  - understanding the constraints among the sub-systems
  - the bounds for plausible thermal loading strategies.
- **Neither a thermal loading decision nor underground thermal tests at the repository site are needed**
  - to do a conceptual design of the entire system
  - to allow construction design of the storage and transportation sub-systems.
- **However, there will be programmatic consequences from not making a thermal loading decision for conceptual design.**

# **Consequences of Not Making an Early Thermal Loading Decision**

---

- **The Repository Advanced Conceptual Design will have to accommodate thermal loads ranging from 20 to 140 kW/acre.**
  - **Single flexible design**
  - **Multiple optimized designs**
- **The Storage and Transportation subsystems will have to maintain flexibility to accommodate thermal loads ranging from 20 to 140 kW/acre.**
  - **Loading of the MPU would be in the range of 1 to 4 PWR assemblies.**
  - **This would not prevent loads of up to 24 PWR assemblies in the storage, transport and disposal casks.**
  - **Selection of a 21 or 24 PWR MPC would pre-select for the Extended Dry option and introduce risk into the MGDS program.**
- **Cost projections for the MGDS may need to show a range rather than a single value.**

# **Options for Advanced Conceptual Design Without Thermal Tests in Repository Block**

---

- **Carry out early heater tests in offsite test facility.**
- **Show that selected thermal loading option is acceptable even without field tests.**
- **Adopt a repository design that is not sensitive to heat load of the unit capsules.**
- **Carry multiple designs through Advanced Conceptual Design.**

# **Technically supportable approaches to selecting a thermal loading option**

---

## **In order of technical desirability**

- **Avoid selection until heater test results are available.**
- **Identify a favored option, but assure that no irreversible steps are taken that might preclude an alternate which relied on different technical mechanisms.**
- **Identify and quantify the programmatic risk of each option, select the apparently most favorable, and proceed at risk.**

## **Conclusions**

---

- **The basis of a technically sound thermal loading decision is underground test data.**
- **A thermal loading decision can be made now by accepting the consequences**
  - **Added risk and required flexibility for future changes.**
- **A near-term thermal loading decision is not needed in the repository sub-system**
  - **Advanced conceptual design of the repository can be done without making a thermal loading decision**
  - **A thermal loading decision is not needed until license application design.**
- **Design of the transport and storage sub-systems would be affected by the absence of a thermal loading decision**
  - **Some MPC designs are compatible only with an Extended Dry repository.**