

U.S. DEPARTMENT OF ENERGY  
OFFICE OF CIVILIAN RADIOACTIVE WASTE MANAGEMENT

**NUCLEAR WASTE TECHNICAL REVIEW BOARD**

**SUBJECT: THERMAL MANAGEMENT STRATEGY**

**PRESENTER: RICHARD D. SNELL**

**PRESENTER'S TITLE  
AND ORGANIZATION: OPERATIONS MANAGER, ENGINEERING & INTEGRATION  
CRWMS MANAGEMENT AND OPERATING CONTRACTOR  
LAS VEGAS, NV**

**TELEPHONE NUMBER: (702) 295-5168**

OCTOBER 9-10, 1996  
ARLINGTON, VA

# **Thermal Management Strategy**

- **Overall strategy**
- **Thermal goals**
- **Testing**
- **Design and operational considerations**
- **Issues**
- **Summary**

# Thermal Loading Considerations

- **Definition**
  - **Thermal loading is due to the mass loading of waste per unit area, usually measured in MTU/acre**
- **Objective of the reference thermal loading range**
  - **Use thermal loading to create a dry low-humidity drift that does not rewet until after Waste Package surface temperatures have fallen well below the water boiling temperature**

# **Thermal Loading Considerations**


(continued)

- **Impacts of thermal loading options**
  - **Waste Package design, subsurface design, surface design, site characterization, and performance assessment are affected significantly by the choice of thermal options**
- **Implementation approach**
  - **Studies provided recommendations for requirements**
  - **Have developed a Thermal Loading Strategy**
  - **Progressing with designs and design evaluations**
  - **Initiated an integrated thermal testing program**

# Thermal Loading Strategy

- **The repository design should accommodate at least the statutory maximum capacity of 70,000 MTU**
- **The reference thermal loading range is 80-100 MTU/acre**
- **Use testing and modeling to provide reasonable assurance that thermal loading aspects of the design meet performance objectives**
- **Retain flexibility to accommodate alternative thermal loads**

# Thermal Goals, Assumptions and Requirements




# Thermal Goals

- **The following goals are being reevaluated because they are currently identified as strong design drivers**
- **Cladding temperature limit ( $<350^{\circ}\text{C}$ ) retained due to potential performance benefit (1-2 orders of magnitude)**
  - **Related secondary goal for backfill, thermal conductivity  $>0.4$  to  $0.5$  W/m·K for the ACD design, if the backfill is emplaced just before repository closure**
- **Drift wall temperature limit ( $<200^{\circ}\text{C}$ ) retained to limit ground support goals**
  - **Based on conservative calculations of thermal stress and rock expansion**

# Geochemistry Thermal Goals

- The goal of a 115°C limit at the TSw2/TSw3 interface will be deleted
  - No technical basis was found for the goal
- The goal of a 115°C limit in the CHn unit will be modified, as below, to protect the zeolites
- The new goal will be a 90°C limit 170 m below the repository horizon
  - This is the depth to most of the zeolite layer
  - About 10-15% of the area will have some zeolites above this layer
  - The goal is compatible with much of the reference thermal loading range






# Testing

- **Laboratory tests**
  - Thermal, mechanical, hydrological properties of the matrix and rock mass
  - Processes such as imbibition, mineral dehydration, and fracture closure
- **Corrosion tests**
  - Accelerated tests of multiple materials and environments in tanks
  - ThermoGravimetric Apparatus tests
  - Potentiostatic tests
- ***In situ* coupled process tests**
  - Accelerated to observe thermal phenomena

# Thermal Test Timeline




# Single Heater Test

- **First thermal test in the Exploratory Studies Facility**
- **Test instrumentation for the drift scale test**
- **Rock properties for geomechanical design**
- **Began on schedule August 26, 1996**
- **Approximately one year of heating**
- **35 instrument holes, >600 instrument channels**




# Corrosion Test Facility

- Waste Package reference design materials (alloy 625, carbon and stainless steels) and alternate materials (e.g. hastelloys, titanium, copper alloys)
- Typical (J-13 water) and three bounding (acidic, alkaline, concentrated J-13) environments
- Includes galvanic (cathodic protection) tests
- Phased activation, Phase 1 began testing in September 1996



# Drift Scale Test

- **Coupled thermal-mechanical-hydrological-chemical processes**
- **Full diameter drift and canister heaters**
- **47.5 m of drift with 12.5 m cast-in-place concrete liner section**
- **2-4 years of heating, depending on processes that are observed in the first two years**
- **Heater activation scheduled for late calendar year 1997**
- **144 instrument holes, ~6500 instrument channels**




# **Thermal Management Operational Techniques Evaluated**

- **Controlling emplacement sequence of Waste Packages or Spent Nuclear Fuel (SNF) assemblies**
  - **Waste Package sequencing reduced power variation between Waste Packages by 4x (due to aging)**
  - **SNF assembly sequencing reduced power variation between Waste Packages by 10x**
- **Higher thermal loading at repository edges**
  - **The current design does not use enhanced edge loading because recent calculations do not indicate a large benefit. This issue will not be revisited during the VA design period**
- **Ventilation**
  - **The current design does not ventilate emplacement drifts because of increased cost and complexity**

# Thermal Management Operational Techniques Evaluated

(continued)

- For thermal loads below 100 MTU/acre, the Waste Packages can be spread as “points” in a “square” spacing, or concentrated in more widely spaced drifts (line loading)
- Line loading reduces the Waste Package to Waste Package temperature variation and drift construction costs, but generates somewhat higher temperatures for the hottest Waste Packages
- Line loading is an option under consideration for design implementation



# Operational Considerations

- **Some subsurface sequencing of sealed Waste Packages could be used to allow optimal sequencing of Waste Packages in drifts, particularly if the sequencing area is well ventilated**
- **Emplacement drifts could be either completely filled prior to moving to the next drift, or several drifts could be filled simultaneously**
  - **It will take two to three months to fill a drift, if that is the only drift being filled**
  - **Even one year is a small time when compared with the amount of time for heat to conduct across the pillar of rock between drifts**
  - **Having several drifts open could help in sequencing hot and cold Waste Packages, thereby reducing lag storage requirements**



# **Issue: Effects of Higher Percolation Flux on Design**

- **Current designs and performance assessments are based on a percolation flux of 0 to 0.3 mm/yr**
- **Recent site characterization data indicate that a flux of 1 to 10 mm/yr may be more appropriate**
- **Preliminary calculations for an 83 MTU/acre indicate that at 1 to 5 mm/yr there is less dryout and relative humidity reduction**

# **Issue: Effects of Higher Percolation Flux on Design**

(continued)

- **Design has several options**
  - **Increase thermal loading (to offset the flux)**
  - **Decrease the thermal loading and use more robust waste package materials**
- **This issue will be studied more during design development for VA**

# **Summary: Thermal Management Decisions (Current Status)**

- **Decisions made**

- **Established a design basis thermal loading range (80-100 MTU/acre)**
- **Selected most thermal management options for VA**
  - » **Line loading is still being evaluated**
- **Determined the initial thermal and corrosion testing program needed to support VA and LA**